



LAKE • GEORGE
WATERKEEPER®

PO Box 591, Lake George, NY 12845

Tel: (518) 668-5913 Fax: (518)-668-5915

Email: info@lakegeorgewaterkeeper.org

www.lakegeorgewaterkeeper.org

May 13, 2009

Mr. Galen Seerup, Chairman
Town of Putnam Planning Board
123 Lower Road
Putnam Station, NY 12861

Re: Connor – 5163 Sagamore Road

Dear Mr. Seerup:

The Lake George Waterkeeper has reviewed the application material for the above referenced site plan and would like to offer the following comments regarding the application:

- 1. Is stormwater management proposed for the house to be located 130 feet from Lake George?**
The plan proposes a 10'x10'x1.5' basin for the driveway but there is no information for stormwater management for the house.
- 2. Information should be provided for the on-site wastewater treatment system (OWTS).**
No information is provided for the OWTS. Will the existing wastewater treatment system be utilized? What are the components of the system? What is the design flow? What is the number of bedrooms for the proposed house? Will the system require pumping or will it be placed closer to the lake than the house which is 130' from the lake? If the existing system is to be utilized, the system should be certified by the licensed professional engineer.
- 3. What are the clearing limits propose for the project? Will a buffer be provided along the lake?**

Thank you for your consideration. The Lake George Waterkeeper looks forward to working with the Town of Putnam Planning Board in defending the natural resources of Lake George and its watershed.

Sincerely,

Christopher Navitsky, PE
Lake George Waterkeeper

cc: Mike White – Lake George Park Commission



THE FUND for LAKE GEORGE